



LEARN MORE AT  
energystar.gov

# ENERGY STAR® Progress & Goals Report

# 99

ENERGY STAR®  
Score<sup>1</sup>

## Electronica - Edif 630

**Primary Property Function:** Office  
**Gross Floor Area (ft²):** 18,222  
**Built:** 1941

**For Year Ending:** June 30, 2014  
**Date Generated:** November 19, 2014

**Property Address:**  
Electronica - Edif 630  
Belt Road, Ramey Base  
Aguadilla, Puerto Rico 00604

**Property ID:** 3790211

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

## Performance Comparison

	Progress			Performance Goals		
	Year Ending 6/30/2009 (Baseline)	Year Ending 6/30/2014 (Selected)	% Change	Property's Target	National Median	ENERGY STAR Score of 75
ENERGY STAR Score	80	99	19	83	50	75

### Energy

Site EUI (kBtu/ft²)	59.1	30.6	93.2	56.1	87.5	64.7
Source EUI (kBtu/ft²)	185.5	96	93.2	176.2	274.8	203.2
\$	72,119.54	39,344.8	-45.45	68,513.56	112,590.65	83,189.82
\$/ft²	3.96	2.16	-45.45	3.76	6.18	4.57

### Greenhouse Gas Emissions

Metric Tons CO2e/year	177.2	91.7	-48.25	168.3	262.5	194
kgCO2e/ ft2/year	9.7	5	-48.25	9.2	14.4	10.6

### Water

All Water Consumption (kgal)	114.1	221.9	94.48	*	*	*
Indoor Water Consumption (kgal)	N/A	N/A	N/A	*	*	*
Indoor Water Consumption (kgal/ft²)	N/A	N/A	N/A	*	*	*
\$	2,914.36	7,242.4	148.51	*	*	*

\*Setting and managing water targets is not yet available in Portfolio Manager.